

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 16-51-2549426
Name of Facility: Jacksonville Classical Academy East, Inc
Address: 5900 Ft Caroline Road
City, Zip: Jacksonville 32277

Type: Public Charter School
Owner: Jacksonville Classical Academy East, Inc.
Person In Charge: Chris Gossett Phone: (904) 302-0052
PIC Email: CGossett@jacksonvilleclassical.org

Correct By: Next Inspection
Re-Inspection Date: None

Inspection Information

Purpose: Routine
Inspection Date: 1/13/2025

Begin Time: 12:30 PM
End Time: 12:50 PM

Additional Information

FEMALES 102
MALES 104

CENSUS 715

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION	IN 11. Group Toilet Rooms	IN 21. Pest Control
IN 1. School Site	IN 12. Toilet Facilities	SAFETY
IN 2. Playground, Equip & Athletic Fields*	OUT 13. Handwashing Facilities	IN 22. First Aid Kit
NA 3. Athletic & Playground Equipment	IN 14. Soap Dispensers	DIAPER CHANGING STATION
BUILDING CONST/MAINT.	NA 15. Shower Facilities	NA 23. Sanitizers
IN 4. Construction	NA 16. Showers Water Temperatures	NA 24. Changing Station & Mats
IN 5. Maintenance & Repair	WATER SUPPLY	NA 25. Hand Sink
IN 6. Lighting Standards	IN 17. Approved Source	NA 26. Garbage Can
IN 7. Heating, Ventilation, A/C Standards	IN 18. Drinking Fountains	ANIMAL HEALTH & SAFETY
IN 8. Natural Ventilation	LIQUID WASTE & WASTE WATER	NA 27. Animal Maintenance/Aggressive
IN 9. Mechanical Ventilation	IN 19. Sewage Disposal	DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	IN 20. Solid Waste	NA 28. Maintenance/Complaint
IN 10. Provided/Accessible/Separation	PEST CONTROL	NA 29. Other

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

*Violation Key: * = 2. Playground, Equipment & Athletic Fields*

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

General Comments

Floors walls and ceilings are in good condition
Classrooms, art room, music room, cafeteria, playground, and other key school areas were checked during inspection.
One paper towel dispenser in boys stall in bathroom outside of room 210 was empty during inspection. Facility informed and dispenser was properly restocked by staff. corrected on site
Maintenance areas are stockeed and properly secured
No pests observed during inspection
All areas are clean and in good condition
Conditions are satisfactory at this time

Email Address(es): CGossett@jacksonvilleclassical.org

Violations Comments

Violation #13. Handwashing Facilities
One paper towel dispenser in boys stall in bathroom outside of room 210 was empty during inspection. Facility informed and dispenser was properly restocked by staff. corrected on site
CODE REFERENCE: 13. Handwashing Facilities. 5(13)(h)1 SREF. Hot and cold water shall be provided in toilet rooms at the lavatory. Hot water temperature shall not exceed 110°F. 468.3.5.7.1 FBC. Handwashing facilities shall be located within or adjoining each toilet room.

Inspection Conducted By: Ethan Bower (68844)
Inspector Contact Number: Work: (904) 253-1280 ex.
Print Client Name:
Date: 1/13/2025

Inspector Signature:

Client Signature: